

Not Just a Lot of Hot Air!

In-line calibrating an Annubar® Primary Flow Element
in unconventional ductwork or plumbing.

Short Course: 6A-4890

**COMBINING
THE ELEMENTS**



Photography & Video Recording Policy



Photography and audio/video recording is not permitted in any sessions or in the exhibition areas without press credentials or written permission from the Emerson Exchange Board of Directors. Inquiries should be directed to:

EmersonExchange@Emerson.com

Thank you.

Presenters



- **Dave Winters**



- **Nate Kenyon**

ROSEMOUNT®

Dave Winters: Bio



- Field Service Engineer
- Based out of Rosemount DP Flow in Boulder, CO
- 35 years of service to Rosemount DP Flow
- Experience
 - Drafting
 - Design
 - Field Service: Experiences include flowmeter installations, start-ups, and in-line calibration

Nate Kenyon: Bio



- Product Development Engineer
- Also based out of Rosemount DP Flow in Boulder, CO
- Experience:
 - Skid design
 - Antifreeze/coolant processing plant
 - Flowmeter configuration management
 - Rosemount DP Flow projects outside standard product offering

In-Line Calibration - Introduction

■ Focusing on air flow:



- You will learn how an Annubar® Averaging Pitot Tube works.
- You will learn how an S-Type (Stauscheibe) Pitot Tube works.
- You will learn how to perform an in-line calibration.



- You will learn how to obtain an accurate reading from an Annubar® APT installed in less than ideal conditions.


In-Line Calibration - Introduction




- We may inadvertently use the following terms interchangeably:

In-Line Calibration	Flow Coefficient	Annubar® Primary Element
Pitot Traverse	K-Factor	485
Flow Test	Blockage Coefficient	Annubar® APT (Averaging Pitot Tube)
In-Situ Calibration		
In-Line Flow Calibration		

Annubar® Primary Element Basics



Annubar® Primary Element Basics



- The Annubar® primary element creates a blockage in the process piping (Model 485 is shown).
- Process fluid accelerates to fit the same amount of fluid flow through the smaller area.
- Since energy must be conserved the process pressure decreases as velocity increases.
- The transmitter measures the difference in pressure and calculates flow rate.


Any Questions?

Annubar® Primary Element Installation



■ Dream Conditions

- 8 upstream and 4 downstream diameters of straight pipe (or more)
- No valves, elbows, reducers, holes, expanders, etc. in front of measurement point
- Annubar® APT installed perpendicular to pipe axis within 3°
- Smooth wall pipe
- Fully developed flow profile
- No moisture, particulate or condensate
- Measured pipe ID (used for calculation)



In-Line Calibration - Introduction





Upstream/Downstream Condition	Recommended 'A'	Recommended 'B'
	8D in plane 10D out of plane	4D
	11D in plane 16D out of plane	4D
	23D in plane 26D out of plane	4D
	30D in plane 30D out of plane	4D
	12D in plane 12D out of plane	4D

Table taken from the 485 QIG
(Quick Installation Guide)


In-Line Calibration - Introduction

- Why do you need an In-Line Calibration?
 - Annubar® APT is installed in less than ideal conditions
 - Lack of straight run
 - Odd-shaped or large ducting
 - Non-standard mounting
 - Fan or dampers in close proximity
 - 'Manifold' of primary elements
 - Temperature gradient in flow
 - Flow reading is not representative of actual flow



In-Line Calibration


- Introduction: An in-line flow calibration is used to adjust the K-Factor (or flow coefficient) of the Annubar® APT so that the DP reading from the bar matches the actual, non-standard flow through the pipe or duct.




- First, we determine the actual flow through the pipe.
- Then we adjust the K-Factor that has been programmed into the transmitter (or customer's control system) to account for the non-standard flow profile.

In-Line Calibration

- Where did it come from?
 - The actual Pitot Traverse is done following the guidelines of Code of Federal Regulations (CFR) number 40, part 60
- Where does the Pitot Traverse take place?
 - At or near the location of an existing Annubar® primary element, the Pitot tube is used to determine the actual flow rate, compensating for any special conditions.



Preferred Flow Testing Location




Stauscheibe Pitot
(aka: "S-type" or open face)

Any Questions?

In-Line Calibration - Introduction


■ What are the steps to an In-Line Calibration?

- Split the pipe or duct into numerous equal area segments near the Annubar® APT
- Use an S-type Pitot tube to measure the DP (flow) through each segment
- Adjust the Annubar® APT flow coefficient to make the flow or DP reading match the total flow determined from the Pitot Tube measurements



In-Line Calibration - Introduction


Divide the duct interior into numerous equal area segments



Section A-A from previous slide

In-Line Calibration - Introduction


Add access ports for
the S-type Pitot Tube



Section A-A from previous slide

In-Line Calibration - Introduction


Insert the S-type Pitot
Tube into the access
port



Section A-A from previous slide

In-Line Calibration - Introduction


Record DP readings at
each segment of the pipe
from the Pitot Tube



Section A-A from previous slide


In-Line Calibration - Introduction

- Use area, temperature, pressure, blockage and recorded DP from the S-type Pitot Tube in each segment to determine actual flow
- Compare to Annubar® APT's reading
- Adjust the primary element's flow coefficient to match




In-Line Calibration - Introduction

- Pipe or Round Duct



In-Line Calibration - Introduction



Prior to In-Line Calibration



- Obtain customer information
 - Fan curve
 - Line/Duct size and wall thickness
 - Mounting information
 - Fluid information
 - Type of fluid: Air, natural gas, steam, etc.
 - Temperature of fluid
 - Process pressure on fluid
- Enter this information into a quoting and calculation program called “Instrumentation Toolkit” to predict the DPs and K-factor

Prior to In-Line Calibration

- Instrument Toolkit Calculation Datasheet
 - Customer inputs
 - Calculated outputs
 - Warnings, structural failure information

ROSEMOUNT INC. 485 - Annubar Primary Element CALCULATION DATA SHEET																																																									
GENERAL DATA Customer: Various Project: Nalle Canyon S. O. No.: P. O. No.: Calc. Date: Model No: 485G0802DHP01T100R7RL Tag No: EMEX-DEMO-AR-430F																																																									
PRODUCT DESCRIPTION Product Type: Pak-Lok Sensor Size: 1 Instrument Valve: Valve Material: Welded Material: 316 Stainless Steel Transmitter Conn.: Remote-Mount NPT Connections Mounting Conn. Material: 316 Stainless Steel Mounting Type: Compression/Threaded Connection Line Size: 8-in. (200 mm) Pipe Orientation: Horizontal																																																									
INPUT DATA <table border="0"> <tr> <td>Fluid Type:</td> <td>Gas</td> <td>Wall:</td> <td>0.100 inch</td> </tr> <tr> <td>Fluid Name:</td> <td>AIR</td> <td></td> <td></td> </tr> <tr> <td>Pipe I.D. (Span):</td> <td>8.250 inch</td> <td>Equivalent Pipe ID:</td> <td>7.064 inch</td> </tr> <tr> <td>Body I.D.:</td> <td>8.250 inch</td> <td>Base Pressure:</td> <td>14.696 psia</td> </tr> <tr> <td>Duct Width:</td> <td>4.750 inch</td> <td>Base Temperature:</td> <td>60.00 F</td> </tr> <tr> <td>Pressure at Flow:</td> <td>0.200 inH2O@60F-g</td> <td></td> <td></td> </tr> <tr> <td>Temperature at Flow:</td> <td>430.00 F</td> <td></td> <td></td> </tr> <tr> <td>Absolute Viscosity:</td> <td>0.0060 cP</td> <td>Base Density:</td> <td>0.0742 lb/ft3</td> </tr> <tr> <td>Isentropic Exponent:</td> <td>1.390</td> <td>Atmospheric Pressure:</td> <td>14.696 psia</td> </tr> <tr> <td>Compressibility at Flow:</td> <td>1.0002</td> <td></td> <td></td> </tr> <tr> <td>Density at Flow:</td> <td>0.0446 lb/ft3</td> <td>(Primary Dimension):</td> <td></td> </tr> </table> <table border="0"> <tr> <td>Flow Rates:</td> <td></td> </tr> <tr> <td>Minimum:</td> <td>400.00 ACFM</td> </tr> <tr> <td>Normal:</td> <td>600.00 ACFM</td> </tr> <tr> <td>Maximum:</td> <td>800.00 ACFM</td> </tr> <tr> <td>Full Scale:</td> <td>800.00 ACFM</td> </tr> </table>				Fluid Type:	Gas	Wall:	0.100 inch	Fluid Name:	AIR			Pipe I.D. (Span):	8.250 inch	Equivalent Pipe ID:	7.064 inch	Body I.D.:	8.250 inch	Base Pressure:	14.696 psia	Duct Width:	4.750 inch	Base Temperature:	60.00 F	Pressure at Flow:	0.200 inH2O@60F-g			Temperature at Flow:	430.00 F			Absolute Viscosity:	0.0060 cP	Base Density:	0.0742 lb/ft3	Isentropic Exponent:	1.390	Atmospheric Pressure:	14.696 psia	Compressibility at Flow:	1.0002			Density at Flow:	0.0446 lb/ft3	(Primary Dimension):		Flow Rates:		Minimum:	400.00 ACFM	Normal:	600.00 ACFM	Maximum:	800.00 ACFM	Full Scale:	800.00 ACFM
Fluid Type:	Gas	Wall:	0.100 inch																																																						
Fluid Name:	AIR																																																								
Pipe I.D. (Span):	8.250 inch	Equivalent Pipe ID:	7.064 inch																																																						
Body I.D.:	8.250 inch	Base Pressure:	14.696 psia																																																						
Duct Width:	4.750 inch	Base Temperature:	60.00 F																																																						
Pressure at Flow:	0.200 inH2O@60F-g																																																								
Temperature at Flow:	430.00 F																																																								
Absolute Viscosity:	0.0060 cP	Base Density:	0.0742 lb/ft3																																																						
Isentropic Exponent:	1.390	Atmospheric Pressure:	14.696 psia																																																						
Compressibility at Flow:	1.0002																																																								
Density at Flow:	0.0446 lb/ft3	(Primary Dimension):																																																							
Flow Rates:																																																									
Minimum:	400.00 ACFM																																																								
Normal:	600.00 ACFM																																																								
Maximum:	800.00 ACFM																																																								
Full Scale:	800.00 ACFM																																																								
CALCULATED DATA (Calculation Performed at Normal Conditions.) <table border="0"> <tr> <td>DP at Min Flow:</td> <td>0.258 inH2O@60F</td> <td>Flow Coefficient:</td> <td>0.5507</td> </tr> <tr> <td>DP at Normal Flow:</td> <td>0.581 inH2O@60F</td> <td></td> <td></td> </tr> <tr> <td>DP at Max Flow:</td> <td>1.034 inH2O@60F</td> <td>Rod Reynolds Number (Minimum):</td> <td>3005</td> </tr> <tr> <td>DP at Full Scale Flow:</td> <td>1.034 inH2O@60F</td> <td>Rod Reynolds Number (Normal):</td> <td>4507</td> </tr> <tr> <td>Resonant Frequency:</td> <td>404 Hz</td> <td>Gas Expansion Factor:</td> <td>0.9999</td> </tr> <tr> <td>Wake Frequency:</td> <td>149 Hz</td> <td>Permanent Pressure Loss:</td> <td></td> </tr> <tr> <td>Blockage:</td> <td>0.12</td> <td>at Normal Flow:</td> <td>0.07 inH2O@60F</td> </tr> <tr> <td></td> <td></td> <td>at Maximum Flow:</td> <td>0.13 inH2O@60F</td> </tr> <tr> <td></td> <td></td> <td>Velocity at Max Flow:</td> <td>48.65 ft/sec</td> </tr> </table>				DP at Min Flow:	0.258 inH2O@60F	Flow Coefficient:	0.5507	DP at Normal Flow:	0.581 inH2O@60F			DP at Max Flow:	1.034 inH2O@60F	Rod Reynolds Number (Minimum):	3005	DP at Full Scale Flow:	1.034 inH2O@60F	Rod Reynolds Number (Normal):	4507	Resonant Frequency:	404 Hz	Gas Expansion Factor:	0.9999	Wake Frequency:	149 Hz	Permanent Pressure Loss:		Blockage:	0.12	at Normal Flow:	0.07 inH2O@60F			at Maximum Flow:	0.13 inH2O@60F			Velocity at Max Flow:	48.65 ft/sec																		
DP at Min Flow:	0.258 inH2O@60F	Flow Coefficient:	0.5507																																																						
DP at Normal Flow:	0.581 inH2O@60F																																																								
DP at Max Flow:	1.034 inH2O@60F	Rod Reynolds Number (Minimum):	3005																																																						
DP at Full Scale Flow:	1.034 inH2O@60F	Rod Reynolds Number (Normal):	4507																																																						
Resonant Frequency:	404 Hz	Gas Expansion Factor:	0.9999																																																						
Wake Frequency:	149 Hz	Permanent Pressure Loss:																																																							
Blockage:	0.12	at Normal Flow:	0.07 inH2O@60F																																																						
		at Maximum Flow:	0.13 inH2O@60F																																																						
		Velocity at Max Flow:	48.65 ft/sec																																																						
GUIDELINES <table border="0"> <tr> <td>Primary Element Min Limit:</td> <td>865.37 ACFM</td> <td>Recommended Min Rod Reynolds Number:</td> <td>5500</td> </tr> <tr> <td>Structural Limit (Flow):</td> <td>13994.11 ACFM</td> <td>Recommended Min DP:</td> <td>0.100 inH2O@60F</td> </tr> <tr> <td>Structural Limit (DP):</td> <td>3119 inH2O@60F</td> <td></td> <td></td> </tr> <tr> <td>Max. Allow. Pressure@Temp.:</td> <td>27916.1 inH2O@60F-g</td> <td>430 F</td> <td></td> </tr> <tr> <td>Design Pressure/Temperature:</td> <td>0.20 inH2O@60F-g</td> <td>430.00 F</td> <td>Max. Allow. Temp.: 550 F</td> </tr> </table>				Primary Element Min Limit:	865.37 ACFM	Recommended Min Rod Reynolds Number:	5500	Structural Limit (Flow):	13994.11 ACFM	Recommended Min DP:	0.100 inH2O@60F	Structural Limit (DP):	3119 inH2O@60F			Max. Allow. Pressure@Temp.:	27916.1 inH2O@60F-g	430 F		Design Pressure/Temperature:	0.20 inH2O@60F-g	430.00 F	Max. Allow. Temp.: 550 F																																		
Primary Element Min Limit:	865.37 ACFM	Recommended Min Rod Reynolds Number:	5500																																																						
Structural Limit (Flow):	13994.11 ACFM	Recommended Min DP:	0.100 inH2O@60F																																																						
Structural Limit (DP):	3119 inH2O@60F																																																								
Max. Allow. Pressure@Temp.:	27916.1 inH2O@60F-g	430 F																																																							
Design Pressure/Temperature:	0.20 inH2O@60F-g	430.00 F	Max. Allow. Temp.: 550 F																																																						
WARNINGS																																																									
* Flowrate is below recommended minimum value of 865.367568 ACFM.																																																									
NOTES This report is provided according to the terms and conditions of the Instrument Toolkit(TM) End-Use Customer License Agreement. Version: 3.0 (Build16300) Printed On: 26-Aug-2013																																																									

Prior to In-Line Calibration



- Sizing the Annubar® Primary Element in Instrumentation Toolkit:

ROSEMOUNT INC. 485 - Annubar Primary Element CALCULATION DATA SHEET			
GENERAL DATA			
Customer:	Various		
Project:	Nate Kenyon and Dave Winters		
S. O. No:			
P. O. No:			
Calc. Date:	August 26, 2013		
Model No:	485G080ZSHPS1T100R7RL / 3051SFA1G080ZSHPS1T100T31DA1A5RLQ4M5		
Tag No:	EMEX-DEMO-AIR-430F		
PRODUCT DESCRIPTION			
Product Type:	485 Duct Mount	Instrument Valve:	
Sensor Size:	Sensor Size 1	Valve Material:	
Wetted Material:	316 Stainless Steel	Line Size:	8.25" X 4.75"
Transmitter Conn.:	Remote-Mount NPT Connections	Pipe Sch.:	
Mounting Conn. Material:	316 Stainless Steel	Pipe Orientation:	Horizontal
Mounting Type:	Duct Flange		

Prior to In-Line Calibration

- Sizing the Annubar® Primary Element in Instrumentation Toolkit:

We field verify duct dimensions prior to in-line calibration

INPUT DATA

Fluid Type: Gas

Fluid Name: AIR

Pipe I.D. (Span): 8.250 inch

Body I.D.: 8.250 inch

Duct Width: 4.750 inch

Pressure at Flow: 0.200 inH₂O@60F-g

Temperature at Flow: 430.00 F

Absolute Viscosity: 0.02660 cP

Isentropic Exponent: 1.390

Compressibility at Flow: 1.0002

Density at Flow: 0.0446 lb/ft³

Flow Rates

Minimum: 400.00 ACFM

Normal: 600.00 ACFM

Maximum: 800.00 ACFM

Full Scale: 800.00 ACFM

Wall: 0.100 inch

Equivalent Pipe ID: 7.064 inch

Base Pressure: 14.696 psia

Base Temperature: 60.00 F

Base Density: 0.0764 lb/ft³

Atmospheric Pressure: 14.696 psia

[Primary Dimension]:

From Customer's Original Order

Prior to In-Line Calibration

■ Sizing the Annubar® Primary Element in Instrumentation Toolkit:

Customer's original flow coefficient from initial Toolkit sizing calculation. This is the flow coefficient in the transmitter "out of the box".

CALCULATED DATA				
(Calculation Performed at Normal Conditions.)				
DP at Min Flow:	0.258 inH2O@68F	Flow Coefficient:	0.5567	
DP at Normal Flow:	0.581 inH2O@68F			
DP at Max Flow:	1.034 inH2O@68F	Rod Reynolds Number (Minimum):	3005	
DP at Full Scale Flow:	1.034 inH2O@68F	Rod Reynolds Number (Normal):	4507	
Resonant Frequency:	404 Hz	Gas Expansion Factor:	0.9999	
Wake Frequency:	149 Hz	Permanent Pressure Loss:		
Blockage:	0.12	at Normal Flow:	0.07 inH2O@68F	
		at Maximum Flow:	0.13 inH2O@68F	
		Velocity at Max Flow:	48.65 ft/sec	
GUIDELINES				
Primary Element Min Limit:	865.37 ACFM	Recommended Min Rod Reynolds Number:	6500	
Structural Limit (Flow):	13984.11 ACFM	Recommended Min DP:	0.100 inH2O@68F	
Structural Limit (DP):	315.8 inH2O@68F			
Max. Allow. Pressure@Temp.:	27818.1 inH2O@60F-ζ	430 F	Max. Allow. Temp.:	850 F
Design Pressure/Temperature:	0.20 inH2O@60F-ζ	430.00 F		

Any Questions?

Annubar® APT Installation: Real Condition 1

Annubar®
Head


In-Line
Calibration
Test Ports

Flow

Annubar®
Tip


**Annubar® installed directly after Fan in
Windbox Expansion/Transition Duct**

Annubar® APT Installation: Real Condition 2



Hot Air Ducting


Annubar® APT Installation: Real Condition 2



GENERAL ARRANGEMENT

**VENTURI SECTION
RETRO-FIT PROJECT (1)**
DSI ARTWORK No. 81-49123-008


Annubar® APT Installation: Real Condition 4



- Downstream of dampers and elbows
- Upstream of conditioners and elbow
- Unknown velocity profile




Annubar® APT Installation: Real Condition 5




Annubar® APT Installation: Real Condition 5

■ Conditions:

- Upstream dynamic dampers
- Structural supports both up and down
- Measurement in reducing accelerator
- Downstream turning vanes



Annubar® APT Installation: Real Condition 6



MITERED ELBOW

ANNUBAR FLOW ELEMENT

(2) IN-LINE CALIBRATION PORTS

DUCT BELLOW


SQUARE TO ROUND TRANSITION

FAN

Any Questions?


Are you sure?

Demonstration Unit



Demonstration Unit

Top View:




Demonstration Unit

Side View:


Mitered Elbow

Turning Vane

Decrease in Duct Height




Demonstration Unit



Demonstration Unit

Looking Inside:

Duct Area at Annubar® 485 = Width at Annubar® 485 Center Line x Height of Duct




Demonstration Unit

Looking Inside:

Duct Area at Pitot Test Ports = Width at Test Port Center Line x Height of Duct

Structural Support
Creates Additional
Disturbance

Duct Height



Duct Width at
Test Ports

Test Port Center Line

Any Questions?

Live In-Line Calibration



■ Traverse Set-Up:

- Duct dimensions at Annubar® Primary Element are verified to match the original customer order:
 - Annubar® APT is a Rosemount Model 485/T1 size installed in a 8.25"(209.6mm) Wide x 4.75"(120.6mm) Tall Duct
 - Duct area at the Annubar® APT is 39.2in^2 (25,277.8mm²)
- Duct dimensions at Pitot test ports:
 - Duct size at the Pitot tube test ports is 7.75"(196.8mm) x 4.75"(120.6mm) Tall
 - Duct area at the Pitot tube test ports is 36.8in^2 (23,748.3mm²)

- Traverse Set-Up Continued:
 - For the Pitot traverse the duct area is divided in to 15 equal areas
 - The Pitot traverse will take place with the fan speed set at maximum
 - Factory Fan Rating, 747 SCFM
 - Process temperature will be set at 430°F
 - All transmitter calibrations, output and signal loops are verified

Live In-Line Calibration



- Data Collection Sheet Ready for test

DIETERICH STANDARD - PITOT TRAVERSE DATA						JOB	
Customer		EMERSON EXCHANGE, 2013.		Date	OCT 2013	DS Tech	BCW BK
Site		GRAPEVINE, TEXAS		Contact THE BARTENDER			
Description				IN-LINE CALIBRATION OF 8.25" MODEL Tag No. EE-DEMO-31			
485/T-1 ANNULAR IN FAN DISCH. DUCT				Primary S/N			
No. of Axes	3	Pts./Axis	5	Time (Start/Finish)			
Pipe/Duct Dimensions		8.25" x 4.75" (209.6 x 120.6 mm)		Primary Span		8.25" (209.6 mm)	
Pitot Type	7/8" S-TYPE	K =	0.84	S/N	PSFS40419 (8")	Barom. 24.87 Hg	
Ref. Flow Rate/Load		MAXIMUM FAN		MW (or Ms)	28.965	SG	
Test Port/Axis No.		1, 2 & 3		%O ₂		%CO ₂	
Test No.		AVERAGING @ 15 SECONDS		%O ₂		%	AIR
Pt. No.	Point Dim. FROM OPPOSITE WALL	Primary 485/T-1 *	Pitot 5/8" S-TYPE	Temp.	Press.		
AXIS	INCHES	INCHES	INCHES	°F			
1 1	4.8" / 1/2"						
2 1	1.43" / 1/2"						
3 1	2.38" / 2 3/8"						
4 1	3.38" / 3 3/8"						
5 1	4.28" / 4 1/4"						
1 2	4.8" / 1/2"						
2 2	1.43" / 1/2"						
3 2	2.38" / 2 3/8"						
4 2	3.38" / 3 3/8"						
5 2	4.28" / 4 1/4"						
1 3	4.8" / 1/2"						
2 3	1.43" / 1/2"						
3 3	2.38" / 2 3/8"						
4 3	3.38" / 3 3/8"						
5 3	4.28" / 4 1/4"						
NOTES: * - 3051 SMV OUTPUT TO SA-DART SET @ 0-4" W.C. † - EQUIVALENT PIPE INSIDE DIAMETER: 7.664 DIA. ‡ - AREA @ ANNULAR 39.2 SQ. IN. § - DUCT INSIDE DIMENSIONS @ PITOT: 7.75" x 4.75" (36.8 SQ. IN.)							

Live In-Line Calibration

■ Almost Ready

- Now, plant operations will hold fan speed/damper to desired flow rate
- **Avoid discharge end of duct for safety reasons**
- For this demonstration some assumptions or simulations may be made such as barometric pressure, process temperature, etc.
- If we start running out of time we will use pre-prepared data
- ANY QUESTIONS?
- **Don't throw objects in the fan!**
- Finally! . . Lets turn the fan on and record some numbers!

“CLICK...”

“WIRRRRRR....”

Live In-Line Calibration

DIETERICH STANDARD - PITOT TRAVERSE DATA					JOB		
Customer		EMERSON EXCHANGE, 2013.		Date	OCT 2013	DS Tech	DAW BK
Site		GRAPEVINE, TEXAS		Contact			THE BARTENDER
Description		IN-LINE CALIBRATION OF 8.25" MODEL		Tag No.			EE-DEMO-31
		4BS/T-1 ANNULAR IN FAN DISCH. DUCT		Primary Span			ORIG. "K" = .5570
No. of Axes	3	Pts./Axis	5	Time (Start/Finish)			
Pipe/Duct Dimensions		8.25" x 4.75" (209.6 x 120.6 mm)		Primary Span		18.25" (209.6 mm)	
Pitot Type		1/8" S-TYPE		K =	0.84	S/N	PSFS400019 (8)
Ref. Flow Rate/Load		MAXIMUM FAN		MW (or Ms)	28.965	SG	
Test Port/Axis No.		1, 2 & 3		%O ₂		%CO ₂	
Test No.		AVERAGING @ 15 SECONDS		%O ₂		%	AIR
Pt. No.	Point Dim. FROM OPPOSITE WALL	Primary 4BS/T-1 * INCHES	Pitot 1/8" S-TYPE INCHES	Temp. °F	Press. INCHES		
1	.48" / 1/2"	.56"	.40"	430°	.075"		
2	1.43" / 1 1/2"	.56"	.61"	↓	↓		
3	2.38" / 2 3/8"	.56"	.73"	430°	↓		
4	3.38" / 3 3/8"	.56"	.72"	↓	.075"		
5	4.28" / 4 1/4"	.56"	.58"	↓	↓		
- AXIS NO.							
1	2.48" / 1/2"						
2	1.43" / 1 1/2"						
3	2.38" / 2 3/8"						
4	3.38" / 3 3/8"						
5	4.28" / 4 1/4"						
1	3.48" / 1/2"						
2	1.43" / 1 1/2"						
3	2.38" / 2 3/8"						
4	3.38" / 3 3/8"						
5	4.28" / 4 1/4"						
NOTES: * - 30515MV OUTPUT TO SA-DART SET @ 0-.4" W.C. ▲ - EQUIVALENT PIPE INSIDE DIAMETER: 7.064 DIA. ▼ - AREA @ ANNULAR 39.2 SQ. IN. ○ - DUCT INSIDE DIMENSIONS @ PITOT: 7.75" x 4.75" (36.8 SQ. IN.)							

- Completed Traverse in Axis 1

Live In-Line Calibration

■ Completed Traverse in Axis 2

DIETERICH STANDARD - PITOT TRAVERSE DATA						JOB	
Customer		EMERSON EXCHANGE, 2013		Date	OCT 2013 DS Tech <u>DCW BK</u>		
Site		GRAPEVINE, TEXAS		Contact	THE BARTENDER		
Description		IN-LINE CALIBRATION OF 8.25" MODEL		Tag No.	EE-DEMO-31		
485/T-1 ANNULAR IN FAN DISCH. DUCT		Primary SPN		ORIG. "K"	.5570		
No. of Axes	3	Pts./Axis	5	Time (Start/Finish)			
Pipe/Duct Dimensions	8.25" x 4.75" (209.6 x 120.6 mm)			Primary Span	18.25" (209.6 mm)		
Pitot Type	7/8" S-TYPE		K =	0.84	S/N	PSF340019 (8")	
Ref. Flow Rate/Load	MAXIMUM FAN		MW (or Ms)	28.965	SG		
Test Port/Axis No.	1, 2 & 3		%O ₂		%CO ₂		
Test No.			AVERAGING @ 15 SECONDS	%O ₂		%	AIR
Pt. No.	Point Dim. FROM WALL	Primary 485/T-1 * INCHES	Pitot 5/8" S-TYPE INCHES	Temp. °F	Press. INCHES		
1	1.48" / 1/2"	.56"	.40"	430°	.075"		
2	1.43" / 1/2"	.56	.61"	↓	↓		
3	2.38" / 2 3/8"	.56	.73	430°	↓		
4	3.38" / 3 3/8"	.56	.72	↓	.075		
5	4.28" / 4 1/4"	.56	.58	↓	↓		
- AXIS NO							
1	2.48" / 1/2"	.55"	.28"	430°	.075		
2	1.43" / 1/2"	.56	.39"	↓	↓		
3	2.38" / 2 3/8"	.55	.27"	↓	↓		
4	3.38" / 3 3/8"	.56	.20	↓	.075		
5	4.28" / 4 1/4"	.54	.18"	430°	↓		
1	3.48" / 1/2"						
2	3.43" / 1/2"						
3	2.38" / 2 3/8"						
4	3.38" / 3 3/8"						
5	4.28" / 4 1/4"						

NOTES: * - 3051 SMV OUTPUT TO SA-DART SET @ 0-4" W.C.
 ▲ - EQUIVALENT PIPE INSIDE DIAMETER: 7.064 DIA.
 ▼ - AREA @ ANNULAR 39.2 SQ. IN.
 ○ - DUCT INSIDE DIMENSIONS @ PITOT: 7.75" x 4.75" (36.8 SQ. IN.)

Live In-Line Calibration

Completed Traverse in Axis 3

DIETERICH STANDARD - PITOT TRAVERSE DATA						JOB	
Customer		EMERSON EXCHANGE, 2013.		Date	OCT 2013	DS Tech	DCW BK
Site		GRAPEVINE, TEXAS		Contact			THE BARTENDER
Description		IN-LINE CALIBRATION OF 8.25" MODEL		Tag No.	EE-DEMO-31		
		485/7-1 ANNULAR IN FAN DISCH. DUCT		Primary SN	ORIG. "K" = .5570		
No. of Axes	3	Pts./Axis	5	Time (Start/Finish)			
Pipe/Duct Dimensions	8.25" x 4.75" (209.6 x 120.6 mm)			Primary Span	18.25" (209.6 mm)		
Pitot Type	5/8" S-TYPE			K =	0.84		
Ref. Flow Rate/Load	MAXIMUM FAN			SN	PSFS400019 (8")		
Test Port/Axis No.	1, 2 & 3			MW (or Ms)	28.965		
				SG			
Test No.	AVERAGING @ 15 SECONDS			%O ₂	%CO ₂		
				%O ₂	AIR		
Pt. No.	Point Dim. FROM OPPOSITE WALL	Primary 485/7-1 * INCHES	Pitot 5/8" S-TYPE INCHES	Temp. °F	Press. INCHES		
1 1	4.8" / 1/2"	.56"	.40"	430°	±.075"		
2 1	1.43" / 1 1/2"	.56	.61"	↓	↓		
3 1	2.38" / 2 3/8"	.56	.73	430°	↓		
4 1	3.38" / 3 3/8"	.56	.72	↓	.075		
5 1	4.28" / 4 1/4"	.56	.58	↓	↓		
← AXIS NO.							
1 2	4.8" / 1/2"	.55"	.28"	430°	±.075		
2 2	1.43" / 1 1/2"	.56	.39"	↓	↓		
3 2	2.38" / 2 3/8"	.55	.27"	↓	↓		
4 2	3.38" / 3 3/8"	.56	.20	↓	.075		
5 2	4.28" / 4 1/4"	.54	.18"	430°	↓		
•							
1 3	4.8" / 1/2"	.55"	.22"	430°	±.075"		
2 3	1.43" / 1 1/2"	.55"	.40	↓	↓		
3 3	2.38" / 2 3/8"	.56"	.54	↓	↓		
4 3	3.38" / 3 3/8"	.55"	.55	430°	↓		
5 3	4.28" / 4 1/4"	.55"	.38	↓	↓		
NOTES: * - 3051 SMV OUTPUT TO SA-DART SET @ 0-.4" W.C. ▲ - EQUIVALENT PIPE INSIDE DIAMETER: 7.064 DIA. ▼ - AREA @ ANNULAR 39.2 SQ. IN. ○ - DUCT INSIDE DIMENSIONS @ PITOT: 7.75" x 4.75" (36.8 SQ. IN.)							

Live In-Line Calibration



- Acquisition of “raw-test-data” is now complete
- At this point, plant operations would be notified to adjust fan to another speed or return to normal operations.
- Raw data will be entered in to the calibration spreadsheet
- The calibration spreadsheet will calculate new “K-Factor”

Live In-Line Calibration

Dieterich Standard - Pitot Traverse Data														
Customer:Emerson Exchange 2013				Job Number:				Tag Number:EE-DEMO-31-72F-Calibrated				DSI Tech: Dave Winters & Nate Kenyon		
Site: Grapevine, Texas				Job Contact: Bartender				Pitot S/N: PSFS400019				Date: October 2013		
Discription: Emerson Exchange "Not Just a Lot of Hot Air"								Comments/Notes: Original K-Factor: 0.5567						
PITOT INPUTS			PITOT OUTPUTS			ANNUBAR INPUTS			ANNUBAR OUTPUTS			FLUID PROPERTY INPUTS		
Pitot Type: S/B S-Type			Pipe Area: 36.31 Inch ²			Sensor Size: T1			Duct Area: 39.1875 inch ²			Fluid: Air		
Calibrated K = 0.84			Eqiv. Diameter Dep: 6.846 inch			Probe Width: 0.59 inch			Eqiv. Diameter Dep: 7.064 inch			Density: 0.076356 lb/ft ³		
Strut Dia = 0.625 inch			Avg Corr. Vel-Trav: 50.700 ft/sec			Blockage Coeff. C1: -1.515			Blockage B: 12.42%			Density Temp: 60 F		
Tip Dia = 0.188 inch			Calc'd Flow Rate: 778.9 ACFM			Blockage Coeff. C2: 1.4229			Ave Measured DP: 0.55 inH2O			Density Press: 14.73 PSIA		
Tip Length = 3 inch			Calc'd Flow Rate: SCFM			Duct Height @ Annubar: 8.25 inch			Ave Measured Flow: 644.93 ACFM			Barometric: 24.87 inHg		
Pitot Strut Cd = 1.2						Duct Width @ Annubar: 4.75 inch			Ave Measured Temp: 430 F			inH2O/PSI @ 60F: 0.036139633 Conversion		
Duct Height @ Pitot: 4.75 inch						Conversion Factor Final: 5.9823			Ave Density: 0.03685			inHg/PSI @ 60: 0.489770685 Conversion		
Duct Width @ Pitot: 7.75 inch						Therm Expan Factor Faa: 1			Ave Gas Exp. Ysp: 1.000			Isentropic Exp: 1.40213		
No. of Axes: 3						Toolkit Flow Coeff. Kpuls: 0.5570			Calib. Flow Coeff Radj: 0.6727 from flow ratio					
Pts./Axis: 5						Toolkit Normal DP: 0.973 inH2O			Calibrated "K-Factor": 0.6727 from flow eqn.					
Rate Units: ACFM						Toolkit Full Scale DP: 1.73 inH2O								
Pitot Direction: OUT						Toolkit Normal Flow: 800 ACFM								
						Toolkit Full Scale Flow: 800 ACFM								
						Toolkit Flow at Max DP: 800 ACFM								
						Calculated K: 0.5569								
Axis 1 - Point No.	Pt Distance-in	Pitot Area-in ²	Blkage-%	Air Temp - F	Static Pressure inH2O	Compressibility	Air Density- lb./ft ³	Pitot DP-in H2O	Calc'd Vel-ft/sec	Blkg Corr	Annubar DP	Gas Exp.Factor Annubar Ysp	Annubar Rate - ACFM	Flow Rate-Corr
1	4.275	1.339	3.69%	430	0.075	1.0026	0.03685	0.40	50.59	0.978	0.56	1.000	642.03	0.995
2	3.325	0.766	2.00%	430	0.075	1.0026	0.03685	0.61	62.48	0.981	0.56	1.000	648.03	0.995
3	2.325	0.445	1.21%	430	0.075	1.0026	0.03685	0.73	68.35	0.983	0.56	1.000	648.03	0.995


Original K-Factor (From Toolkit): 0.5567

New K-Factor (From Pitot Traverse): 0.6727

% Change in K-Factor: 21%



1	4.275	1.339	3.69%	430	0.075	1.0026	0.03685	0.40	50.59	0.978	0.56	1.000	642.22	1.004
2	3.325	0.766	2.00%	430	0.075	1.0026	0.03685	0.60	50.59	0.981	0.55	1.000	642.22	1.004
3	2.375	0.445	1.21%	430	0.075	1.0026	0.03685	0.54	50.78	0.993	0.56	1.000	648.03	0.995
4	1.425	0.267	0.73%	430	0.075	1.0026	0.03685	0.55	59.32	0.996	0.55	1.000	642.22	1.004
5	0.475	0.009	0.24%	430	0.075	1.0026	0.03685	0.38	49.31	0.999	0.55	1.000	642.22	1.004

Flow Profile




Flow Profile


- Different fan settings, damper settings, and all around flow conditions could result in different associated K-Factors



Full Scale
Flow $K=0.672$



Normal Flow
 $K=0.646$



Minimum
Flow $K=0.593$

- Almost Finished!
 - Need to reconfigure the transmitter
 - Using Engineering Assistant (E.A.) the new Corrected Flow coefficient “K-Factor” will be entered in the 3051SMV multi-variable transmitter
- OR
 - Using a Field Communicator (like a 475 Handheld) the output signal (HART, 4-20mA, etc.) signal can be reconfigured to match the new Flow Coefficient.
- OR
 - If the customers data acquisition system is performing the flow calculation from the transmitter output, the new corrected Flow Coefficient will simply be provided to the customer.

Summary



- You have now learned:
 - Annubar® primary element basics
 - Many of the real Annubar® 485 duct installation challenges
 - The process of an in-line flow calibration
 - Performing an in-line flow calibration on an Annubar® allows for repeatable and accurate flow measurement in otherwise impossible to measure process situations

Any Questions?

Where To Get More Information



- More information on Annubar® Primary Elements and Flowmeters can be found:
 - Annubar Flow Handbook
 - <http://www2.emersonprocess.com/siteadmincenter/PM%20Rosemount%20Documents/00809-0100-1191.pdf>
 - Annubar® Flow Test Data Book
 - <http://www2.emersonprocess.com/siteadmincenter/PM%20Rosemount%20Documents/00821-0100-4809.pdf>



Thank You for Attending!

Enjoy the rest of the conference.

**COMBINING
THE ELEMENTS**

